

Office of Station Officer
Fire and rescue Station
Thiruvananthapuram

No. C. 421/2021

Date: 17 April 2021


FIRE & SAFETY INSPECTION REPORT

As per the request of Principal, Mother Therasa Memorial Central School, Pulippara, Pangode P O, vide letter dated 3 April 2021, I have inspected the firefighting arrangements provided in the education building of Mother Therasa Memorial Central School with G+1 height of 7.85 M, plinth area 608 Sqm, survey no: 1861/7-1-1, 1861/5-1-1, 1861/4-1, 1861/1 Pangode Village, Nedumangad Taluk, Thiruvananthapuram and found the following arrangements

1. Fire Extinguisher
2. Hose Reel
3. Down Comer
4. Booster Pump 450LPM
5. Fire Brigade inlet
6. Over Head Tank 10000 Ltr Capacity

The above arrangements were tested and found working satisfactory at the time of inspection.




Station Officer
Fire and rescue Station
Thiruvananthapuram